



Forney, LP
 227 S High St
 Zelienople, PA 16063
<https://forneyonline.com/>
 724-452-9330



Concrete Block Compression Test

Project Number	1600 Pennsylvania	Machine	WIN10_SIM2 F-250-VFD
Location Name	May Flowers	Calibration Date	05/16/2024
Sample Number	321654 S05	Technician	ER
Set Number	28	Sample Date	11/19/2024 10:00


Specimen Data

Specimen Number	1	Shell Thickness	-
Avg. Length	2 in	Web Thickness	0 in
Avg. Width	2 in	Net Area	4 in ²
Avg. Height	2 in	Weight	0 lb
		Age to Break	28 days
		Expected Strength	7,500 psi

Results Data

Test Date	12/17/2024 15:41	Break Load	31,640 lbf
Specimen Age	28 days	Break Stress	7,909.93 psi
Preload	14,800 lbf	Break Type	0
Ramp Rate	34.88 psi/s		
Test Duration	120 seconds		

Block Break Types



https://forneytools.forneyvault.com/Report/97cbfbfc-7c07-46ea-a002-568236e2a047

