



**Forney, LP**  
 227 S High St  
 Zelienople, PA 16063  
<https://forneyonline.com/>  
 724-452-9330



### Concrete Cylinder Compression Test

Project Number	1600 Pennsylvania	Machine	WIN10_SIM2 F-250-VFD
Location Name	May Flowers	Calibration Date	05/16/2024
Sample Number	321654 S01	Technician	ER
Set Number	Cylinder	Sample Date	11/12/2024 08:00




#### Specimen Data

Specimen Number	1	Density	0 lb/ft³
Diameter	4 in	Age to Break	28 days
Length	8 in	Expected Strength	7500 psi
Weight	0 lb	Correction Factor	1

#### Results Data

Test Date	12/10/2024 09:10	Break Load	94,536 lbf
Specimen Age	28 days	Break Stress	7,520 psi
Preload	46,496 lbf	Break Type	3
Ramp Rate	34.95 psi/s		

#### Cylinder Break Types



https://forneytools.forneyvault.com/Report/ce017fa7-3aa8-4e1e1-8b76-439289cabeb8