



Forney, LP
 227 S High St
 Zelienople, PA 16063
<https://forneyonline.com/>
 724-452-9330



Grout Prism Compression Test

Project Number	1600 Pennsylvania	Machine	WIN10_SIM2 F-250-VFD
Location Name	May Flowers	Calibration Date	05/16/2024
Sample Number	4590 GRT	Technician	ER
Set Number	28	Sample Date	12/13/2024 14:00

Specimen Data

Specimen Number	1	Weight	-
Height Avg.	6.96 in	Age to Break	28 days
Width Avg.	3.42 in	Expected Strength	3500 psi
Area	11.66 in		

Results Data

Test Date	01/10/2025 15:29	Break Load	42,527 lbf
Specimen Age	28 days	Break Stress	3,650 psi
Preload	19,826 lbf	Fracture Type	3
Ramp Rate	35.15 psi/s		

Grout Prism Break Types



https://forneytools.forneyvault.com/Report/e1390d30-33b8-4f13-9496-10244a84a1fe

