



Forney, LP
 227 S High St
 Zelienople, PA 16063
<https://forneyonline.com/>
 724-452-9330



Concrete Other Compression Test

Project Number	1600 Pennsylvania	Machine	WIN10_SIM2 F-250-VFD
Location Name	May Flowers	Calibration Date	05/16/2024
Sample Number	485236 S01	Technician	ER
Set Number	28	Sample Date	11/29/2024 11:10


Specimen Data

Specimen Number	1	Age to Break	28 days
Length	7 in	Expected Strength	7250 psi
Area	12.25 in ²		
Weight	-		


Results Data

Test Date	12/27/2024 15:21	Break Load	91,334 lbf
Specimen Age	28 days	Break Stress	7,455.87 psi
Preload	500 lbf		
Ramp Rate	34.99 psi/s		

Specimen Load



Specimen Stress



https://forneytools.forneyvault.com/Report/74f8c573-04a7-41e1-8fe3-e061097a6c91